

STATE LEVEL ENVIRONMENT IMPACT ASSESSMENT AUTHORITY

No. SIA/MH/MIS/120554/2019
 Environment Department
 Room No. 217, 2nd Floor,
 Mantralaya,
 Mumbai- 400032.
 Date:08.07.2020.

To
 M/s.GARNET BUILDERS AND DEVELOPERS
 Sr.no.26, Hissa no.-3, Sr.no.27, Hissa no.-1(P),
 Village Sus, Taluka Mulshi, District- Pune

Subject : Environment Clearance for CONSTRUCTION Project at Sr.no.26, Hissa no.-3, Sr.no.27, Hissa no.-1(P), Village Sus, Taluka Mulshi, District- Pune by M/s.GARNET BUILDERS AND DEVELOPERS

Reference : Application no. SIA/MH/MIS/120554/2019

This has reference to your communication on the above mentioned subject. The proposal was considered by the SEAC-3 in its 108th meeting under screening category 8 (a) B2 as per EIA Notification, 2006 and recommend to SEIAA. Proposal then considered in 200th meeting of State Level Environment Impact Assessment Authority (SEIAA).

2. Brief Information of the project submitted by you is as below:-

Name of Project	Residential & commercial project on Sr.no.26, Hissa no.-3, Sr.no.27, Hissa no.-1(P), Village Sus, Taluka Mulshi, District- Pune	
Project category	Infrastructure and Miscellaneous Projects + CRZ	
Type of Institution	Private	
Project Proponent	Name	Manoj Oswal, Garnet Builders & Developers
	Regd. Office address	Pinnacle Pride 1, CTS 1544A/1545, 101, Tilak Road, Sadashiv Peth, Pune 411030.
Consultant	VK: e Environmental LLP Pune	
Applied for	New Construction Project	
Details of previous EC	NA	
Location of the project	Pinnacle Pride 1, CTS 1544A/1545, 101, Tilak Road, Sadashiv Peth, Pune 411030	
Latitude and Longitude	18°32'59.50"N, 73°53'50.20"E	
Total Plot Area (m2)	18600	
Deductions (m2)	3997.91 (Road Deductions + Amenity Space)	
Net Plot area (m2)	14602.09	
Proposed FSI area (m2)	26385.54	
Proposed non-FSI area (m2)	28923.51	
Proposed TBUA (m2)	55309.05	
TBUA (m2) approved by Planning Authority till date	55309.05 m ² DATED 28/01/2020	
Ground coverage (m2) & %	4603.07	
Total Project Cost (Rs.)	98,09,60,160	
Details of Building Configuration:		Reason for

Previous EC / Existing Building			Proposed Configuration			Modification / Change
Building	Configuration	Height	Building	Configuration	Height (m)	NA
			Wing A	B+P+14 Floor	42.9	
			Wing B	B+P+14 Floor	42.9	NA
			Wing C	B+P+14 Floor	42.9	NA
			Wing D	B+P+14 Floor	42.9	NA
			Wing E	B+P+14 Floor	42.9	NA
			Wing F	B+P+14 Floor	42.9	NA
			Commercial 1	2B+P+ 3 Floor	15.60	NA
			Commercial 1	2B+P+ 3 Floor	15.60	NA
Total number of tenements			Residential:336 Shops & offices: 109 Total Populations - Residential Population : 1680 Commercial users: 783 (Commercial 592 + restaurant 191)			
Water Budget	Dry Season (CMD)			Wet Season (CMD)		
	Fresh Water	181	Fresh Water	181		
	Recycled for Flushing	90	Recycled for Flushing	90		
	Swimming Pool	5	Swimming Pool	0		
	Landscaping	27	Landscaping	0		
	Total water requirement	303	Total water requirement	271		
	Waste water generation	233	Waste water generation	233		
Water Storage Capacity for Firefighting/UG T	250 m3 capacity of underground water storage tank & 120 m3 capacity of overhead fire water tank .					
Source of water	PMC					
Rainwater Harvesting (RWH)	Level of the Ground water table:		pre monsoon water levels are 11.4 m b .g .l Post monsoon water levels 6.2 m b .g .l.			
	Size and no of RWH tank(s) and Quantity:		-			
	Quantity and size of recharge pits:		11 1m x 1m and 1.2m below storm water inlet level with bore-well of 60 m			
	Details of UGT tanks if any:		-			
Sewage and Wastewater	Sewage generation in CMD:		233			
	STP technology:		MBBR			
	Capacity of STP (CMD):		320			
Solid Waste Management during Construction Phase	Type	Quantity (kg/d)	Treatment / disposal			
	Dry waste:	8	Will be handed over to SWaCH			
	Wet waste:	12	Will be operated in OWC			
	Construction waste	-	The construction waste generated during construction shall be segregated, reused on site and surplus shall be led to scrap dealers for recycling			
Solid Waste	Type	Quantity (kg/d)	Treatment / disposal			
	Dry waste:	482	Will be handed over to SWACH			

Management during Operation Phase	Wet waste:	650	Treated with OWC	
	Hazardous waste:	NA	NA	
	Biomedical waste	NA	NA	
	E-Waste	4.44	Will be Handed over to Hi tech recyclers	
	STP Sludge (dry)	24	Used as manure for Landscaping	
Green Belt Development	Total RG area (m ²):		2327.24	
	Existing trees on plot:		01	
	Number of trees to be planted:		210	
	Number of trees to be cut:		00	
	Number of trees to be transplanted		00	
Power requirement:	Source of power supply:		MSEDCL	
	During Construction Phase (Demand Load):		143 kVA	
	During Operation phase (Connected load):		2988.80 KW	
	During Operation phase (Demand load):		1414.84 KW	
	Transformer:		630 kVA (3 nos.)	
	DG set:		1 x 250 KVA, 1 x 100 KVA, 2 x 320 KVA	
	Fuel used:		HSD	
Details of Energy saving	Total Energy Saving : i.e. (18 % Savings) /year, Energy saving due to solar :i.e. (8.34 % Savings)			
Environmental Management plan budget during Construction phase	Sr. No.	Details		Cost
	1	Erosion control – dust suppression measures, barricading and topsoil preservation		17,49,616/-
	2	Labour Camp toilets & sanitation		4,80,000/-
	3	Labour Safety Equipment's and training		4,00,000/-
	4	Environmental Monitoring		3,26,500/-
	5	Disinfection and Health Check-ups		51,000/-
	6	Environmental Monitoring Cell		1,70,000/-
		Total		31,77,116/-
Environmental Management plan Budget during Operation phase	Component	Details	Capital (Rs.)	O&M (Rs./Y)
	Sewage treatment	303 KLD STP	68,00,000/-	12,09,900/-
	RWH	11 nos of Recharge pits	11,00,000/-	1,00,000/-
	Solid Waste	OWC plant	25,75,000/-	5,44,710/-
	Green belt development		43,00,000/-	6,00,000/-
	Energy saving	Solar PV	20,60,000/-	41,200/-
	Environmental Monitoring	Air, Noise, water, OWC manure	-	1,85,600/-
	Lightning Arrester Cost	-	23,22,000 /-	-
Traffic Management	Type	Required as per DCR	Actual Provided	Area per parking (m2)
	4-Wheeler	140	140	12.50 sqm.
	2-Wheeler	734	734	2.00 sqm

Bicycles	734	734	0.70 sqm
Details of Court cases / litigations w.r.t. the project and project location if any.			NA

3. The proposal has been considered by SEIAA in its 200th meeting and decided to accord Environment Clearance to the said project under the provisions of Environment Impact Assessment Notification, 2006 subject to implantation of following terms and conditions-

Specific Conditions:

- i. PP to ensure that CER plan gets approved from Municipal Commissioner.
- ii. PP Shall comply with Standard EC conditions mentioned in the Office Memorandum issued by MoEF& CC vide F.No.22-34/2018-IA.III dt.04.01.2019.
- iii. SEIAA decided to grant EC for –FSI: 26385.54 m², Non-FSI: 28923.51 m² and Total BUA: 55309.05 m² (Plan Approval no-CR 40-18-20/Sus/CTS no 26-2/26 (P), Dated-28.01.2020)

General Conditions:

- i. E-waste shall be disposed through Authorized vendor as per E-waste (Management and Handling) Rules, 2016.
- ii. The Occupancy Certificate shall be issued by the Local Planning Authority to the project only after ensuring sustained availability of drinking water, connectivity of sewer line to the project site and proper disposal of treated water as per environmental norms.
- iii. This environmental clearance is issued subject to obtaining NOC from Forestry & Wild life angle including clearance from the standing committee of the National Board for Wild life as if applicable & this environment clearance does not necessarily implies that Forestry & Wild life clearance granted to the project which will be considered separately on merit.
- iv. PP has to abide by the conditions stipulated by SEAC& SEIAA.
- v. The height, Construction built up area of proposed construction shall be in accordance with the existing FSI/FAR norms of the urban local body & it should ensure the same along with survey number before approving layout plan & before according commencement certificate to proposed work. Plan approving authority should also ensure the zoning permissibility for the proposed project as per the approved development plan of the area.
- vi. If applicable Consent for Establishment" shall be obtained from Maharashtra Pollution Control Board under Air and Water Act and a copy shall be submitted to the Environment department before start of any construction work at the site.
- vii. All required sanitary and hygienic measures should be in place before starting construction activities and to be maintained throughout the construction phase.
- viii. Adequate drinking water and sanitary facilities should be provided for construction workers at the site. Provision should be made for mobile toilets. The safe disposal of wastewater and solid wastes generated during the construction phase should be ensured.
- ix. The solid waste generated should be properly collected and segregated. Dry/inert solid waste should be disposed of to the approved sites for land filling after recovering recyclable material.
- x. Disposal of muck during construction phase should not create any adverse effect on the neighbouring communities and be disposed taking the necessary precautions for general safety and health aspects of people, only in approved sites with the approval of competent authority.
- xi. Arrangement shall be made that waste water and storm water do not get mixed.
- xii. All the topsoil excavated during construction activities should be stored for use in horticulture / landscape development within the project site.
- xiii. Additional soil for levelling of the proposed site shall be generated within the sites (to the extent possible) so that natural drainage system of the area is protected and improved.
- xiv. Green Belt Development shall be carried out considering CPCB guidelines including selection of plant species and in consultation with the local DFO/ Agriculture Dept.
- xv. Soil and ground water samples will be tested to ascertain that there is no threat to ground water quality by leaching of heavy metals and other toxic contaminants.
- xvi. Construction spoils, including bituminous material and other hazardous materials must not be

allowed to contaminate watercourses and the dumpsites for such material must be secured so that they should not leach into the ground water.

- xvii. Any hazardous waste generated during construction phase should be disposed of as per applicable rules and norms with necessary approvals of the Maharashtra Pollution Control Board.
- xviii. The diesel generator sets to be used during construction phase should be low sulphur diesel type and should conform to Environments (Protection) Rules prescribed for air and noise emission standards.
- xix. The diesel required for operating DG sets shall be stored in underground tanks and if required, clearance from concern authority shall be taken.
- xx. Vehicles hired for bringing construction material to the site should be in good condition and should have a pollution check certificate and should conform to applicable air and noise emission standards and should be operated only during non-peak hours.
- xxi. Ambient noise levels should conform to residential standards both during day and night. Incremental pollution loads on the ambient air and noise quality should be closely monitored during construction phase. Adequate measures should be made to reduce ambient air and noise level during construction phase, so as to conform to the stipulated standards by CPCB/MPCB.
- xxii. Fly ash should be used as building material in the construction as per the provisions of Fly Ash Notification of September 1999 and amended as on 27th August, 2003. (The above condition is applicable only if the project site is located within the 100Km of Thermal Power Stations).
- xxiii. Ready mixed concrete must be used in building construction.
- xxiv. Storm water control and its re-use as per CGWB and BIS standards for various applications.
- xxv. Water demand during construction should be reduced by use of pre-mixed concrete, curing agents and other best practices referred.
- xxvi. The ground water level and its quality should be monitored regularly in consultation with Ground Water Authority.³
- xxvii. The installation of the Sewage Treatment Plant (STP) should be certified by an independent expert and a report in this regard should be submitted to the MPCB and Environment department before the project is commissioned for operation. Discharge of this unused treated effluent, if any should be discharge in the sewer line. Treated effluent emanating from STP shall be recycled/ refused to the maximum extent possible. Discharge of this unused treated effluent, if any should be discharge in the sewer line. Treatment of 100% grey water by decentralized treatment should be done. Necessary measures should be made to mitigate the odour problem from STP.
- xxviii. Permission to draw ground water and construction of basement if any shall be obtained from the competent Authority prior to construction/operation of the project.
- xxix. Separation of grey and black water should be done by the use of dual plumbing line for separation of grey and black water.
- xxx. Fixtures for showers, toilet flushing and drinking should be of low flow either by use of aerators or pressure reducing devices or sensor based control.
- xxxi. Use of glass may be reduced up to 40% to reduce the electricity consumption and load on air conditioning. If necessary, use high quality double glass with special reflective coating in windows.
- xxxii. Roof should meet prescriptive requirement as per Energy Conservation Building Code by using appropriate thermal insulation material to fulfil requirement.
- xxxiii. Energy conservation measures like installation of CFLs /TFLs for the lighting the areas outside the building should be integral part of the project design and should be in place before project commissioning. Use CFLs and TFLs should be properly collected and disposed of /sent for recycling as per the prevailing guidelines/rules of the regulatory authority to avoid mercury contamination. Use of solar panels may be done to the extent possible like installing solar street lights, common solar water heaters system. Project proponent should install, after checking feasibility, solar plus hybrid non-conventional energy source as source of energy.
- xxxiv. Diesel power generating sets proposed as source of backup power for elevators and common area illumination during operation phase should be of enclosed type and conform to rules made under the Environment (Protection) Act, 1986. The height of stack of DG sets should be equal

to the height needed for the combined capacity of all proposed DG sets. Use low sulphur diesel. The location of the DG sets may be decided with in consultation with Maharashtra Pollution Control Board.

- xxxv. Noise should be controlled to ensure that it does not exceed the prescribed standards. During night-time the noise levels measured at the boundary of the building shall be restricted to the permissible levels to comply with the prevalent regulations.
- xxxvi. Traffic congestion near the entry and exit points from the roads adjoining the proposed project site must be avoided. Parking should be fully internalized and no public space should be utilized.
- xxxvii. Opaque wall should meet prescriptive requirement as per Energy Conservation Building Code, which is proposed to be mandatory for all air-conditioned spaces while it is aspiration for non-air-conditioned spaces by use of appropriate thermal insulation material to fulfil requirement.
- xxxviii. The building should have adequate distance between them to allow movement of fresh air and passage of natural light, air and ventilation.
- xxxix. Regular supervision of the above and other measures for monitoring should be in place all through the construction phase, so as to avoid disturbance to the surroundings.
 - xl. Under the provisions of Environment (Protection) Act, 1986, legal action shall be initiated against the project proponent if it was found that construction of the project has been started without obtaining environmental clearance.
 - xli. Six monthly monitoring reports should be submitted to the Regional office MoEF, Bhopal with copy to this department and MPCB.
 - xl.ii. Project proponent shall ensure completion of STP. MSW disposal facility, green belt development prior to occupation of the buildings. As agreed during the SEIAA meeting, PP to explore possibility of utilizing excess treated water in the adjacent area for gardening before discharging it into sewer line No physical occupation or allotment will be given unless all above said environmental infrastructure is installed and made functional including water requirement in Para 2. Prior certification from appropriate authority shall be obtained.
 - xl.iii. Wet garbage should be treated by Organic Waste Converter and treated waste (manure) should be utilized in the existing premises for gardening. And, no wet garbage will be disposed outside the premises. Local authority should ensure this.
 - xl. iv. Local body should ensure that no occupation certification is issued prior to operation of STP/MSW site etc. with due permission of MPCB.
 - xl. v. A complete set of all the documents submitted to Department should be forwarded to the Local authority and MPCB.
 - xl. vi. In the case of any change(s) in the scope of the project, the project would require a fresh appraisal by this Department.
 - xl. vii. A separate environment management cell with qualified staff shall be set up for implementation of the stipulated environmental safeguards.
 - xl. viii. Separate funds shall be allocated for implementation of environmental protection measures/EMP along with item-wise breaks-up. These cost shall be included as part of the project cost. The funds earmarked for the environment protection measures shall not be diverted for other purposes and year-wise expenditure should reported to the MPCB & this department.
 - xl. ix. The project management shall advertise at least in two local newspapers widely circulated in the region around the project, one of which shall be in the Marathi language of the local concerned within seven days of issue of this letter, informing that the project has been accorded environmental clearance and copies of clearance letter are available with the Maharashtra Pollution Control Board and may also be seen at Website at <http://parivesh.nic.in>
 - 1. Project management should submit half yearly compliance reports in respect of the stipulated prior environment clearance terms and conditions in hard & soft copies to the MPCB & this department, on 1st June & 1st December of each calendar year.
 - li. A copy of the clearance letter shall be sent by proponent to the concerned Municipal Corporation and the local NGO, if any, from whom suggestions/representations, if any, were received while processing the proposal. The clearance letter shall also be put on the website of the Company by the proponent.
 - lii. The proponent shall upload the status of compliance of the stipulated EC conditions, including results of monitored data on their website and shall update the same periodically. It shall

- simultaneously be sent to the Regional Office of MoEF, the respective Zonal Office of CPCB and the SPCB. The criteria pollutant levels namely; SPM, RSPM, SO₂, NO_x (ambient levels as well as stack emissions) or critical sector parameters, indicated for the project shall be monitored and displayed at a convenient location near the main gate of the company in the public domain.
- liii. The project proponent shall also submit six monthly reports on the status of compliance of the stipulated EC conditions including results of monitored data (both in hard copies as well as by e-mail) to the respective Regional Office of MoEF, the respective Zonal Office of CPCB and the SPCB.
- liv. The environmental statement for each financial year ending 31st March in Form-V as is mandated to be submitted by the project proponent to the concerned State Pollution Control Board as prescribed under the Environment (Protection) Rules, 1986, as amended subsequently, shall also be put on the website of the company along with the status of compliance of EC conditions and shall also be sent to the respective Regional Offices of MoEF by e-mail.

4. The environmental clearance is being issued without prejudice to the action initiated under EP Act or any court case pending in the court of law and it does not mean that project proponent has not violated any environmental laws in the past and whatever decision under EP Act or of the Hon'ble court will be binding on the project proponent. Hence this clearance does not give immunity to the project proponent in the case filed against him, if any or action initiated under EP Act.

5. In case of submission of false document and non-compliance of stipulated conditions, Authority/ Environment Department will revoke or suspend the Environment clearance without any intimation and initiate appropriate legal action under Environmental Protection Act, 1986.

6. The Environment department reserves the right to add any stringent condition or to revoke the clearance if conditions stipulated are not implemented to the satisfaction of the department or for that matter, for any other administrative reason.

7. Validity of Environment Clearance: The environmental clearance accorded shall be valid as per EIA Notification, 2006, amended time to time.

8. In case of any deviation or alteration in the project proposed from those submitted to this department for clearance, a fresh reference should be made to the department to assess the adequacy of the condition(s) imposed and to incorporate additional environmental protection measures required, if any.

9. The above stipulations would be enforced among others under the Water (Prevention and Control of Pollution) Act, 1974, the Air (Prevention and Control of Pollution) Act, 1981, the Environment (Protection) Act, 1986 and rules there under, Hazardous Wastes (Management and Handling) Rules, 1989 and its amendments, the public Liability Insurance Act, 1991 and its amendments.

10. Any appeal against this Environment clearance shall lie with the National Green Tribunal (Western Zone Bench, Pune), New Administrative Building, 1st Floor, D-Wing, Opposite Council Hall, Pune, if preferred, within 30 days as prescribed under Section 16 of the National Green Tribunal Act, 2010.


Anil Diggikar
(Member Secretary, SEIAA)

Copy to:

1. Shri Johnny Joseph, Chairman, SEIAA.
2. Secretary, MoEF & CC
3. IA- Division MOEF & CC
4. Member Secretary, Maharashtra Pollution Control Board, Mumbai.
5. Regional Office MoEF & CC, Nagpur
6. District Collector, Pune.
7. Commissioner, PMRDA
8. Regional Officer, Maharashtra Pollution Control Board, Pune.